



GOVERNMENT OF INDIA (भारत सरकार)
MINISTRY OF RAILWAYS (रेल मंत्रालय)
(RAILWAY BOARD) (रेलवे बोर्ड)

No.2021/EEM/180/11

New Delhi, Dated: 09.11.2021

**General Managers
All Indian Railways &
Production units**

Director General, RDSO, Lucknow

**General Manager(Const)NF Rly., Guwahati
General Manager, CORE, Allahabad**

Director General, NAIR, Vadodara

Sub: Scale of electrical fittings for the existing staff quarters-Standardization thereof.

Ref: Board's letter No.2006/Elect(G)/180/11/Pt. dated 21.06.2016.

The policy guidelines for electrical scale of fittings for existing staff quarters were circulated in past vide Board's letter dated 21.06.2016 under reference above.

2. In super session of the letter under reference above, it has been decided that the revised scale of electrical fittings for the existing staff quarters shall be as per details enclosed in Annexure. These guidelines will be applicable for all the existing staff quarters. However, revised scale of fittings for existing quarters should be provided when re-wiring of a quarter is being undertaken.

3. This letter supersedes all the earlier instructions issued on the subject to the extent they are not in conformity with these instructions.

This issues with the concurrence of Finance directorate and approval of Board (M/TRS).

(Sumit Garg)

Director Elect. Engg. (PS)

Railway Board

Phone:011-23389112

Email-rbelectricalcem@gmail.com

Revised Scale of Fittings in Residential Staff Quarters

Type of Quarters	Name of Points Provided in Quarters													
	Power Points (15 A)	Plug Point (5A)	Bracket Lights	Ceiling Fan	Call Bell Points	Exhaust Fans	AC Points	Geyser Point	EDB/MCB Point (1 ϕ)	EDB/MCB Point (3 ϕ)	Decorative Light Fittings	FL Fitting	Light Point	Modular Switches
Type-II	8	5	4	3	1	3	3	1	1	-	-	4	-	-
Type-III	8	5	4	4	1	4	3	2	1	-	-	4	-	-
Type-IV	12	7	11	6	2	4	5	4	-	1	-	6	-	-
Type-IV Spl.	12	7	11	6	2	4	5	4	-	1	-	6	-	-
Type-V	15	8	10	6	3	4	5	4	-	1	13	6	-	Yes
Type-V Spl.	15	8	10	6	3	4	5	4	-	1	13	6	-	Yes
Type-VI	17	9	12	12	3	5	6	5	-	1	16	7	-	Yes
Type-VII	22	12	12	14	4	5	7	5	-	1	22	9	-	Yes